

TRYON UTILITY REPORT

MONTH OF NOVEMBER 2018

Water metered.....		<u>16,967,538</u> gallons
Water used by Fire Dept.....		<u>-100,000</u>
Estimated loss for breaks		<u>-1,041,687</u>
Other losses-Corley tank overflowing		<u> </u>
Water used for Flushing		<u>-180,000</u>
Total.....		<u>15,645,851</u>
Water Billed.....		<u>-5,912,807</u>
Unaccounted for loss.....		<u>9,733,044</u>
Water loss.....	62.21%	
Water used by Columbus.....		<u>0</u> gallons
Wastewater treated		<u>12.354</u> million gal
Wastewater from CYP.....		<u>3.45</u> million gal
Land applied sludge.....		<u> </u> gallons
Vehicles traveled.....		<u>1,981</u> miles
Hours on backhoe	<u>5</u>	
New water service.....		<u> </u>
Registers or Meters replaced	<u>17</u>	New sewer service..... <u> </u>
Meters relocated.....		Sewer blockage..... <u>9</u>
Water leaks/breaks.....	<u>4</u>	Sewer relocated..... <u> </u>
Valves replaced.....	<u> </u> Size..... <u> </u>	
Valves added.....		
Lines added.....		Manhole repaired or cleaned <u>4</u>
Water lines replaced....	<u> </u> 30'8" mtn line	
Hydrants Replaced	<u> </u> Right-of-way maintenance..... <u> </u> feet	
Hydrants Repaired	<u> </u>	
Overtime:		
Outside.....		<u>43</u> hours
Water Plant.....		<u>97</u> hours
Wastetreatment.....		<u>6</u> hours
Vacation.....		<u>282</u> hours
Sick leave.....		<u>50</u> hours
Holiday pay		<u>216</u> hours
WATER = WORK ORDERS COMPLETED	<u>83</u>	
SEWER = WORK ORDERS COMPLETED	<u>9</u>	

* New water meters are accurate to (+ or -) 5%. As meters age, the accuracy drops. Meters tend to run slower as they age.