

TRYON UTILITY REPORT

MONTH OF OCTOBER 2018

Water metered.....		<u>14,180,774</u> gallons
Water used by Fire Dept.....		<u>0</u>
Estimated loss for breaks		<u>-1,853,435</u>
Other losses-Corley tank overflowing		<u> </u>
Water used for Flushing		<u>-425,000</u>
Total.....		<u>11,902,339</u>
Water Billed.....		<u>-6,779,861</u>
Unaccounted for loss.....		<u>5,122,478</u>
Water loss.....	43.04%	
Water used by Columbus.....		<u>0</u> gallons
Wastewater treated		<u>12.126</u> million gal
Wastewater from CYP.....		<u>1904</u> million gal
Land applied sludge.....		<u>0</u> gallons
Vehicles traveled.....		<u>1,972</u> miles
Hours on backhoe	<u>20</u>	
New water service.....	<u>0</u>	New sewer service..... <u>0</u>
Registers or Meters replaced	<u>40</u>	Sewer blockage..... <u>0</u>
Meters relocated.....	<u>0</u>	Sewer relocated..... <u>0</u>
Water leaks/breaks.....	<u>5</u>	
Valves replaced.....	<u>0</u> Size.....	
Valves added.....	<u>0</u>	
Lines added.....	<u>0</u>	Manhole repaired or cleaned <u>2</u>
Water lines replaced....	<u>1</u> 30'8" mtn line	
Hydrants Replaced	<u>0</u>	Right-of-way maintenance..... <u>0</u> feet
Hydrants Repaired	<u>0</u>	
Overtime:		
Outside.....		<u>18</u> hours
Water Plant.....		<u>42</u> hours
Wastetreatment.....		<u>4</u> hours
Vacation.....		<u>144</u> hours
Sick leave.....		<u>12</u> hours
Holiday pay		<u>168</u> hours
WATER = WORK ORDERS COMPLETED	<u>83</u>	
SEWER = WORK ORDERS COMPLETED	<u>9</u>	

* New water meters are accurate to (+ or -) 5%. As meters age, the accuracy drops. Meters tend to run slower as they age.