

TRYON UTILITY REPORT

Sep-18

Water metered.....		<u>17,949,941</u> gallons
Water used by Fire Dept.....		<u>2,000,000</u> mg
Estimated loss for breaks and flushing.....		<u>5,564,046</u> mg
Total.....		<u>10,385,895</u>
Water Billed.....		<u>5,915,622</u> mg
Unaccounted for loss.....		<u>4,470,273</u> mg
Water loss.....	43.04%	
Water used by Columbus.....		<u>0</u> gallons
Wastewater treated		<u>11.4</u> million gal
Wastewater from CYP.....		<u>2.10</u> million gal
Land applied sludge.....		<u>0</u> gallons
Vehicles traveled.....		<u>1,954</u> miles
Hours on backhoe	<u>1,229</u>	
New water service.....	<u>0</u>	New sewer service..... <u>0</u>
Registers or Meters replaced	<u>35</u>	Sewer blockage..... <u>2</u>
Meters relocated.....	<u>0</u>	Sewer relocated..... <u>0</u>
Water leaks/breaks.....	<u>2</u>	
Valves replaced.....	<u>1</u> Size.....	<u>3/4" setter</u>
Valves added.....	<u>0</u>	
Lines added.....	<u>0</u>	Manhole repaired or cleaned <u>2</u>
Water lines replaced....	<u>0</u>	
Hydrants Replaced	<u>0</u>	Right-of-way maintenance..... <u>1,000</u> feet
Hydrants Repaired	<u>0</u>	
Overtime:		
Outside.....		<u>5</u> hours
Water Plant.....		<u>40</u> hours
Wastetreatment.....		<u>0</u> hours
Vacation.....		<u>83</u> hours
Sick leave.....		<u>2</u> hours
Holiday pay		<u>72</u> hours
WATER = WORK ORDERS COMPLETED	<u>119</u>	
SEWER = WORK ORDERS COMPLETED	<u>6</u>	

* New water meters are accurate to (+ or -) 5%. As meters age, the accuracy drops. Meters tend to run slower as they age.