

TRYON UTILITY REPORT MONTH OF DECEMBER 2018

Water metered.....				<u>18,210,032</u> gallons
Water used by Fire Dept.....				<u>0</u>
Estimated loss for breaks				<u>-20,100</u>
Other losses-Corley tank overflowing				
Water used for Flushing				<u>0</u>
Total.....				<u>18,189,932</u>
Water Billed.....				<u>-5,857,892</u>
Unaccounted for loss.....				<u>12,332,040</u>
Water loss.....		<u>67.80%</u>		
Water used by Columbus.....				<u>0</u> gallons
Wastewater treated				<u>16.1</u> million gal
Wastewater from CYP.....				<u>2</u> million gal
Land applied sludge.....				<u>0</u> gallons
Vehicles traveled.....				<u>2,062</u> miles
Hours on backhoe	<u>14</u>			
New water service.....	<u>0</u>			<u>0</u>
Registers or Meters replaced	<u>8</u>			<u>3</u>
Meters relocated.....	<u>0</u>			<u>0</u>
Water leaks/breaks.....	<u>0</u>			
Valves replaced.....	<u>0</u>	Size.....		
Valves added.....	<u>0</u>			
Lines added.....	<u>0</u>			<u>2</u>
Water lines replaced....	<u>0</u>			
Hydrants Replaced	<u>0</u>	Right-of-way maintenance.....	<u>0</u>	feet
Hydrants Repaired	<u>0</u>			
Overtime:				
Outside.....				<u>25</u> hours
Water Plant.....				<u>32</u> hours
Wastetreatment.....				<u>2</u> hours
Vacation.....				<u>91</u> hours
Sick leave.....				<u>38</u> hours
Holiday pay				<u>216</u> hours
WATER = WORK ORDERS COMPLETED	<u>72</u>			
SEWER = WORK ORDERS COMPLETED	<u>5</u>			

* New water meters are accurate to (+ or -) 5%. As meters age, the accuracy drops. Meters tend to run slower as they age.