

TRYON UTILITY REPORT

Jan-19

Water metered.....		<u>18,037,526</u> mg
Water used by Fire Dept.....		<u>0</u>
Estimated loss for flushing.....		<u>-200,200</u>
Estimated loss for breaks		<u>-905,000</u> mg
Other losses-found leak on 108		<u>-1,339,200</u>
Total.....		<u>15,593,126</u>
Water Billed.....		<u>6,196,947</u> mg
Unaccounted for loss.....		<u>9,396,179</u> mg
Water loss.....	<u>60.26%</u>	
Water used by Columbus.....		<u>0</u> gallons
Wastewater treated		<u>13.229</u> million gal
Wastewater from CYP.....		<u>2.88</u> million gal
Land applied sludge.....		<u>0</u> gallons
Vehicles traveled.....		<u>1,956</u> miles
Hours on backhoe	<u>15</u>	
New water service.....	<u>0</u>	New sewer service..... <u>1</u>
Registers or Meters replaced	<u>46</u>	Sewer blockage..... <u>5</u>
Meters relocated.....	<u>0</u>	Sewer relocated..... <u>0</u>
Water leaks/breaks.....	<u>6</u>	
Valves replaced.....	<u>0</u> Size.....	
Valves added.....	<u>0</u>	
Lines added.....	<u>0</u>	Manhole repaired or cleaned <u>2</u>
Water lines replaced....	<u>0</u>	
Hydrants Replaced	<u>0</u>	Right-of-way maintenance..... <u>0</u> feet
Hydrants Repaired	<u>0</u>	
Overtime:		
Outside.....		<u>31.50</u> hours
Water Plant.....		<u>55</u> hours
Wastetreatment.....		<u>0</u> hours
Vacation.....		<u>20</u> hours
Sick leave.....		<u>29</u> hours
Holiday pay		<u>0</u> hours
WATER = WORK ORDERS COMPLETED	<u>76</u>	
SEWER = WORK ORDERS COMPLETED	<u>4</u>	

* New water meters are accurate to (+ or -) 5%. As meters age, the accuracy drops. Meters tend to run slower as they age.