

TRYON UTILITY REPORT

Feb-19

Water metered.....		<u>14,736,528</u> mg
Water used by Fire Dept.....		<u>0</u>
Estimated loss for flushing.....		<u>-463,200</u>
Estimated loss for breaks		<u>-1,150,000</u> mg
Other losses-found leak on 108		
Total.....		<u>13,123,328</u>
Water Billed.....		<u>5,850,372</u> mg
Unaccounted for loss.....		<u>7,272,956</u> mg
Water loss.....	55.42%	
Water used by Columbus.....		<u>0</u> gallons
Wastewater treated		<u>16.861</u> million gal
Wastewater from CYP.....		<u>2.55</u> million gal
Land applied sludge.....		<u>0</u> gallons
Vehicles traveled.....		<u>1,925</u> miles
Hours on backhoe	<u>10</u>	
New water service.....	<u>1</u>	New sewer service.....
Registers or Meters replaced	<u>7</u>	Sewer blockage.....
Meters relocated.....	<u>0</u>	Sewer relocated.....
Water leaks/breaks.....	<u>5</u>	
Valves replaced.....	<u>1</u> Size.....	<u>8"</u>
Valves added.....	<u>0</u>	
Lines added.....	<u>0</u>	Manhole repaired or cleaned
Water lines replaced....	<u>0</u>	<u>2</u>
Hydrants Replaced	<u>0</u>	Right-of-way maintenance.....
Hydrants Repaired	<u>0</u>	<u>0</u> feet
Overtime:		
Outside.....		<u>31.5</u> hours
Water Plant.....		<u>55</u> hours
Wastetreatment.....		<u>0</u> hours
Vacation.....		<u>20</u> hours
Sick leave.....		<u>29</u> hours
Holiday pay		<u>0</u> hours
WATER = WORK ORDERS COMPLETED	<u>74</u>	
SEWER = WORK ORDERS COMPLETED	<u>4</u>	

* New water meters are accurate to (+ or -) 5%. As meters age, the accuracy drops. Meters tend to run slower as they age.