

TRYON UTILITY REPORT

Mar-19

Water metered.....		<u>14,829,564</u> mg
Water used by Fire Dept.....		<u>0</u>
Estimated loss for flushing.....		<u>-158,000</u>
Estimated loss for breaks		<u>-35,000</u> mg
Other losses-found leak on 108		
Total.....		<u>14,636,564</u>
Water Billed.....		<u>6,135,094</u> mg
Unaccounted for loss.....		<u>8,501,470</u> mg
Water loss.....	58.05%	
Water used by Columbus.....		<u>0</u> gallons
Wastewater treated		<u>16.118</u> million gal
Wastewater from CYP.....		<u>0.34</u> million gal
Land applied sludge.....		<u>0</u> gallons
Vehicles traveled.....		<u>1,494</u> miles
Hours on backhoe	<u>11</u>	
New water service.....	<u>1</u>	New sewer service..... <u>1</u>
Registers or Meters replaced	<u>43</u>	Sewer blockage..... <u>6</u>
Meters relocated.....	<u>0</u>	Sewer relocated..... <u>1</u>
Water leaks/breaks.....	<u>2</u>	
Valves replaced.....	<u>0</u> Size.....	
Valves added.....	<u>0</u>	
Lines added.....	<u>0</u>	Manhole repaired or cleaned
Water lines replaced....	<u>0</u>	
Hydrants Replaced	<u>0</u>	Right-of-way maintenance..... <u>0</u> feet
Hydrants Repaired	<u>0</u>	
Overtime:		
Outside.....		<u>4</u> hours
Water Plant.....		<u>26</u> hours
Wastetreatment.....		<u>2</u> hours
Vacation.....		<u>24</u> hours
Sick leave.....		<u>29</u> hours
Holiday pay		<u>0</u> hours
WATER = WORK ORDERS COMPLETED	<u>96</u>	
SEWER = WORK ORDERS COMPLETED	<u>6</u>	

* New water meters are accurate to (+ or -) 5%. As meters age, the accuracy drops. Meters tend to run slower as they age.